

Fire Underwriters Survey

September 29, 2025

RECOGNITION FOR FIRE INSURANCE GRADING RECEIVED

Municipality of Thames Centre
Thames Centre Fire Department
Superior Tanker Shuttle Service - Accredited

I am pleased to advise you that the above-mentioned fire protection district within the province of Ontario was recently registered in the fire insurance grading index as being accredited for the delivery of Superior Tanker Shuttle Service.

The requirements for this accreditation are stringent and verify that the fire protection district is capable of delivering the minimum accepted fire flows to detached dwellings throughout the fire protection district and within 8 kilometres by road of the below accredited Fire Station. An application towards Commercial Lines (PFPC) insurance has also been achieved by exceeding the 400 IGPM PFPC flow rate requirements. This accreditation is an equivalency to the minimum requirements for hydrant protection, as set out by the insurance industry and the Fire Underwriters Survey.

Fire Underwriters Survey has provided information on fire protection and risk levels to the insurance industry in Canada since 1883. Fire Underwriters Survey was previously operated under the auspices of the Insurers Advisory Organization and CGI; however, is now operated by Opta Information Intelligence.

Should you have any questions or concerns related to the Fire Underwriters Survey, the Superior Tanker Shuttle Service Accreditation process, or any other related area, please contact the offices of Fire Underwriters Survey for further information.

Please note that this accreditation expires on September 27th, 2030 and is valid for the following fire station:

- Fire Station #1 – 2156 Dorchester Road
- Fire Station #2 – 17198 Thorndale Road

Personal Lines Fire Insurance Classification – DPG 3B(S) – Flow Rate of 200 IGPM

Commercial Lines Fire Insurance Classification – PFPC 7(S) – Flow Rate of 410 IGPM

Mark Radejewsky C.Tech
Fire Protection Specialist
Fire Underwriters Survey